

ADDENDUM #1

Freezeout Lake WMA Cold Storage Building (2nd Rebid) FWP #7179102

Near Fairfield, Montana

January 16, 2019

Bidders for the above listed project are hereby notified that the following changes have been made to the bid documents:

1. *Replace Technical Specification 08 3613 SECTIONAL DOORS, Section 2.01.A as follows:*

Sectional Doors – Basis of Design: Wayne-Dalton, Thermospan 200-20.
2. *Add Technical Specification 08 3613 SECTIONAL DOORS, Section 2.01.B.4 as follows:*

4. Raynor TM220 is an acceptable sectional door.
3. *Replace Technical Specification 08 3613 SECTIONAL DOORS, Section 2.02.B as follows:*


B. Door Panels: Steel Construction; outer steel sheet of 20-gauge, 0.0359-inch minimum thickness, flush profile; inner steel sheet 26 or 27-gauge, flat profile; core reinforcement sheet steel roll formed to channel shape, rabbeted weather joints at meeting rails; polyurethane insulation.
4. *Replace Technical Specification 08 3613 SECTIONAL DOORS, Section 2.03.H as follows:*

Lock: inside side mounted slide bolt, spring activated latch bar, exterior handle, interlock switch to deactivate operator when lock is engaged.
5. *Replace Technical Specification 08 3613 SECTIONAL DOORS, Section 2.05.F as follows:*

Electric Operator: trolley type, adjustable safety friction clutch, brake system actuated by independent voltage solenoid controlled by motor starter, enclosed gear driven limit switch, enclosed magnetic cross line reversing starter, mounting brackets and hardware.

6. *Modify DRAWING sheets C4 and C5 as follows:*

Total wall height shall be increase to 16'-0" from floor to top of wall (bottom of truss).


Jeffrey L. Larson, P.E.

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE
DESIGNATED PLACE IN THE BID FORM **AND ON THE FACE OF THE
ENVELOPE.**